

RADION receiver SD

B810



BOSCH

en Reference Guide

Table of contents

1	Introduction	5
1.1	About documentation	5
1.2	Bosch Security Systems, Inc. product manufacturing dates	5
2	General installation	7
2.1	Installation workflow	7
2.2	Unpacking information	8
2.3	Wall tamper switch installation	8
2.4	Magnet cover installation	8
2.5	Complete installation	8
2.6	Maintenance	9
3	RADION receiver SD	10
3.1	Certifications and approvals	10
3.2	UL product requirements	11
3.3	B810 installation	14
3.3.1	B810 configuration	14
3.3.2	Base mounting installation	15
3.3.3	Wiring considerations	15
3.3.4	Programming wireless points in the control panel	16
3.3.5	Enroll point RF ID for wireless points (Auto-learn mode)	18
3.3.6	Walk test (for motion detectors)	18
3.3.7	Signal level and margin	19
3.3.8	Complete the installation	20
3.3.9	B810 system test	20
3.4	External LED states	20
3.4.1	LEDs	22
3.5	Specifications (B810)	22
3.5.1	Battery requirements	23
4	RADION repeater	25
4.1	Installation considerations	25
4.2	Wiring considerations	25
4.3	Specifications	26
4.4	LEDs	26
5	RADION glassbreak	28
5.1	Installation considerations	28
5.2	Testing	29
5.2.1	Test the sensor	29
5.2.2	Hand clap test	31
5.3	Low battery	31
5.4	Wall Tamper Tab	31
5.5	Maintenance	31
6	RADION TriTech	32
6.1	Mounting height and range adjustment	32
6.2	Sensitivity settings	33
6.2.1	Standard sensitivity	33
6.2.2	Intermediate sensitivity	33
6.3	Walk testing	33

7	RADION PIR	35
7.1	Walk testing	35
8	RADION PIR C	37
8.1	Walk testing	37
9	RADION smoke	39
9.1	Battery replacement	40
9.2	Smoke test	40
9.3	Sensitivity test	40
9.4	Test/Silence button	41
9.5	LED	41
9.6	Clean the detector and replace the optical chamber	41
10	RADION contact SM	43
10.1	Installation considerations	43
11	RADION contact RM	45
11.1	Installation considerations	45
12	RADION specialty	47
12.1	Applications for this product	48
12.2	Installation consideration	48
13	RADION universal transmitter	49
13.1	Installation considerations	50
13.2	Reed switch settings	51
14	RADION keyfob	52
14.1	RADION keyfob FB	52
14.2	RADION keyfob TB	53
15	RADION panic	55
16	Appendices	57

1 Introduction

This document contains the basic information that a trained installer needs to install the RADION system. It supplements the documents listed inside the packaging (graphical installation guides).

This reference guide contains:

- A description of the general installation procedure.
- Device-specific installation procedures.
- Specification information.

How to use this document

The information contained in this document is constructed in a manner that is systematic and sequential for the installer on a “point of need” basis. The following represents a basic outline of that information;

- Chapter 1 (this chapter) – introductory information and how to use this document.
- Chapter 2 – basic RADION system-wide general installation information and workflow check list.
- Chapter 3 – RADION receiver-specific installation information.
- Remaining chapters – RADION device-specific installation information.
- Appendix – description of various icons and symbols used within the RADION documentation.

Icons and symbols

When you see the following logo in the RADION graphical installation guides listed in Table 3.1, refer to the appropriate section in this document.



Additional icons and symbols, which appear in the RADION graphical installation guides, are explained in the appendix section of this guide. Refer to the *Appendices, page 57* for more information.

1.1 About documentation

Copyright

This document is the intellectual property of Bosch Security Systems, Inc. and is protected by copyright. All rights reserved.


Trademarks

All hardware and software product names used in this document are likely to be registered trademarks and must be treated accordingly.


1.2 Bosch Security Systems, Inc. product manufacturing dates


Use the serial number located on the product label and refer to the Bosch Security Systems, Inc. website at <http://www.boschsecurity.com/datecodes/>.

The following image shows an example of a product label and highlights where to find the manufacturing date within the serial number.


 **BOSCH**


Model Number
Mat/N: F01Uxxxxxx


7  9
82695 11xxx

8  9
717332 311xxx
09216082027193xxxx

PRODUCT

 **N663**





QTY= 1

2 General installation

Phases of installation

The installation of the RADION system is achieved by following the sequential process as defined in this chapter. Overall, there are four main phases;

- Planning
- Physical installation of the devices
- System enrollment/configuration
- System testing (walk test, pattern test)

It is essential that these steps or phases are adhered to in the order mentioned above for proper functionality and operation.

When installing a RADION system, you must plan your installation based on the control panel and RADION device specifications, and the radio-frequency signal strength (RFSS) between devices, receivers, and control panels.

Installation considerations

- RADION devices are intended only for indoor, dry applications.
- Mount RADION devices on flat, rigid surfaces. Some devices can be optionally corner mounted as indicated in the installation instructions.
- Avoid mounting RADION devices in areas with large, metallic objects, electrical panels, or electric motors. They might reduce the radio-frequency (RF) range of a RADION device.
- Avoid installing the devices where excessive humidity, moisture, or temperatures outside of the acceptable operating range exist.
- Wire all objects according to their specifications.
- RADION devices use batteries of varying types. When installing batteries, observe safety and polarity recommendations as indicated in the documentation for those products.

2.1 Installation workflow

To install, configure, and test the system, use the workflow below and follow in sequential order, from top to bottom, checking each box as you complete a step.



Notice!

Always power down the control panel when connecting modules, or other wiring. Power down the control panel by unplugging the transformer and disconnecting the battery

- Plan the installation of the RADION system
- Install the RADION components (refer to the graphical installation guides and this system reference guide for details)
- Program wireless points in the control panel
- Enroll point RF ID for wireless points
- Verify LED responses on devices
- Perform a local walk test for installed detectors
- Review signal strength and margin of each point
- Complete the installation

2.2 Unpacking information

When unpacking the receiver, repeater, or bill trap device, it is important to remove the cardboard insert as illustrated below;




Figure 2.1: Insert for the receiver and repeater




Figure 2.2: Insert for the bill trap

2.3 Wall tamper switch installation

RADION transmitter devices contain a feature that activates the wall tamper switch located on the base of the device. In order to properly install the device, you must consider the following:

- To properly install a device with active wall tamper functionality, insert a screw in the designated screw slot location.
- Failure to insert a screw into the wall tamper slot prevents the wall tamper feature from generating a tamper signal when the transmitter is pulled away from a wall.

2.4 Magnet cover installation

During the installation of the plastic magnet cover, the cover is not designed to be separated from the base after the base and cover are snapped together. Damage to the plastics may occur if separated.


2.5 Complete installation

Testing the entire RADION system can only be achieved by performing an area wide test through the control panel and corresponding keypad(s). This is achieved by performing an overall service walk test. Refer to your control panel documentation for system-walk, or other system-wide testing procedures.

To ensure proper operation of the RADION devices, test the basic functionality of the device locally. Depending on the RADION device to be tested, perform the following procedures for functionality:

- When testing the receiver, power up the compatible control panel in which the receiver is connected to and observe the LED behavior on the receiver.
- Local walk testing can be performed on the motion detectors as defined in the tritech and PIR chapters of this guide.
- Magnet testing can be performed by opening or closing the door/window in which the magnet is installed on.

2.6 Maintenance



It is recommended to check the battery of each device annually. This will ensure proper operation and functionality of the devices.

Battery Life Extension feature (PIR and TriTech)

In the normal operating mode, an alarm can be transmitted only after three (3) minutes have passed since the previous alarm restoral. This 3 minute lockout time reduces unnecessary RF transmissions in high traffic areas, thereby extending battery life.

3 RADION receiver SD

The B810 is a wireless receiver that connects RADION wireless peripherals to supported Bosch control panels via the SDI2 bus connection. A compatible control panel powers the receiver through the wiring connection. Features include:

- Easy addressing via a rotary switch
- Cover and wall tamper protection
- RFID and configuration data are contained in persistent memory
- External LED
- Detection and reporting radio frequency interference
- Supports supervision of wireless points (504), keyfobs (1000), and repeaters (8)

Use this reference guide along with the control panel's documentation and each device's installation instructions to complete the installation process.

3.1 Certifications and approvals

Listings and approvals

UL

The B810 is UL listed for Commercial/Residential Burglar Alarm Systems, and Household Fire Warning System Units.

Products evaluated by UL

The following products have been evaluated by UL:

- B810 wireless receiver
- RFRP-A repeater
- RFBT-A specialty (billtrap)
- RFDW-SM-A standard door/window contact
- RFDW-RM-A recessed door/window contact
- RFDL-11-A motion detector
- RFPR-12-A PIR motion detector
- RFPR-C12-A PIR motion detector (curtain)
- RFUN-A universal transmitter
- RFSM-A smoke detector
- RFKF-TB-A keyfob
- RFKF-FB-A keyfob
- RFPB-TB-A panic
- RFPB-SB-A panic

Products not evaluated by UL

The following products have not been evaluated by UL:

- RFGB-A glassbreak

UL battery requirements

UL recommends to check the battery of each device annually. This will ensure proper operation and functionality of the devices.

For the RFBT-A bill trap, UL requires the battery to be replaced annually to ensure optimal performance.

Battery testing

To ensure proper functionality of each RADION device, it is recommended to test your batteries annually via your supported control panels wireless diagnostics routine. For specific information related to system diagnostics and battery testing, refer to your supported control panel documentation.

Federal Communications Commission (FCC) Rules

This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

INDUSTRY CANADA (IC) Rules

This device complies with Industry Canada licence-exempt RSS standard(s). Operation is subject to the following two conditions: (1) this device may not cause interference, and (2) this device must accept any interference, including interference that may cause undesired operation of the device.

Le présent appareil est conforme aux CNR d'Industrie Canada applicables aux appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes : (1) l'appareil ne doit pas produire de brouillage, et (2) l'utilisateur de l'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement.

Under Industry Canada regulations, this radio transmitter may only operate using an antenna of a type and maximum (or lesser) gain approved for the transmitter by Industry Canada. To reduce potential radio interference to other users, the antenna type and its gain should be so chosen that the equivalent isotropically radiated power (e.i.r.p.) is not more than that necessary for successful communication.

Conformément à la réglementation d'Industrie Canada, le présent émetteur radio peut fonctionner avec une antenne d'un type et d'un gain maximal (ou inférieur) approuvé pour l'émetteur par Industrie Canada.

Dans le but de réduire les risques de brouillage radioélectrique à l'intention des autres utilisateurs, il faut choisir le type d'antenne et son gain de sorte que la puissance isotrope rayonnée équivalente (p.i.r.e.) ne dépasse pas l'intensité nécessaire à l'établissement d'une communication satisfaisante.

3.2 UL product requirements

For product-specific UL requirements, refer to desired product title below for more information.

RADION Repeater

When selecting a suitable 16.5VAC Class 2 plug in transformer, the following transformers are suggested:

- MG Electronics (MGT-1640)
- Codex SEP-1640

The transformers mentioned above are Primary Rated 120VAC, 60 Hz, 0.48 Amps, Secondary 16.5VAC, 40VA.

When selecting a suitable 18VAC Class 2 plug-in transformer, the following transformers are suggested:

- TDC Part No DA-22-18, Primary Rated 120VAC, 60 Hz, 30VA, Secondary Rated 18VAC, 1.3 Amps, 22VA.

**Notice!**

For UL installations when transformer is used, restraining tab is to be connected.

**Notice!**

For UL installations when a repeater is installed, a minimum of two repeaters must be installed for proper signal routing.

Information related to the internal standby battery is as follows:

- Power/voltage (Standby Battery): Rated 3.7 VDC, 3050mAh, EVE ENERGY CO Part No P0046-LF (Not user replaceable)

**Notice!**

For standby battery to be operative, the tamper switch is required to be engaged.

Standby battery is capable of providing 72 hours of standby power to the RF repeater for a UL Burglar Alarm Installation (Bank Safe and Vault).

- 24 Hours for Household Fire Warning Systems
- 8 Hours for HOLD UP Burglar Alarms
- 4 Hours for Burglar Alarm Mercantile Installations

RADION glassbreak**Notice!**

The RFGB-A has not been investigated by UL, and not part of a UL Listed system.

RADION TriTech**Notice!**

Pet Immunity has not been evaluated by UL.

**Notice!**

Draft and Insect Immunity has not been evaluated by UL.

RADION smoke

For UL installations THIS UNIT INCLUDES AN ALARM VERIFICATION FEATURE THAT WILL RESULT IN A DELAY OF THE SYSTEM ALARM SIGNAL FROM THE INDICATED CIRCUITS. THE TOTAL DELAY (CONTROL UNIT PLUS SMOKE DETECTORS) SHALL NOT EXCEED 60 SECONDS. NO OTHER SMOKE DETECTOR SHALL BE CONNECTED TO THESE CIRCUITS UNLESS APPROVED BY THE LOCAL AUTHORITY HAVING JURISDICTION.

RADION contact SM

During the installation of the device, UL installations primary securement means shall be screws.

RADION contact RM

During the installation of the device, UL installations primary securement means shall be screws.

RADION specialty

When programming the bill trap, special programming for a hold up device is required.

Program the point as follows:

- P## Type = 2 (Point is constantly armed regardless of the status of the system).
- -P## Invisible Point = Yes (Keypads do not display alarm activity from this point).

For UL installations, the RFBT-A shall be permanently mounted using the 3M VHB 4956 double sided adhesive tape. The suitable surfaces are:

- Aluminum
- Galvanized steel
- Stainless steel
- Enameled steel
- Nickel Coated ABS
- Glass (with or without Silane Coating)
- PVC
- Glass/Epoxy
- PBT
- Polycarbonate
- Acrylic/Polyurethane paint
- Polyester paint

RADION universal transmitter

During the installation of the device, the following items are required by UL:

- For UL installations, an UL Listed burglar alarm dry contact device shall be connected if the external terminal is used.
- When external contact is configured for UL hold up installations, a hold up device such as potter electric model HUB is to be connected to the external contact. For programming, refer to the appropriate control panel manual "Special programming required for a hold up device." Point shall be programmed as stated below:
 - P## Type = 1 Instant on open or short (Point is constantly armed regardless of the status of the system).
 - -P## Invisible Point/Silent Bell = Yes (Keypads do not display alarm activity from this point).

Furthermore for UL hold up installations the internal reed switch is to be disabled. The door window contact magnet will not be operative. The transmitter if used for hold up installations shall be dedicated to a holdup installation only. Hold up alarm requires a UL Listed Automation System at the Central Station to show distinction between a Hold Up Alarm and a regular Burglar Alarm.

- For UL installations, a 2.2 K ohm shall be installed.
- For UL installations, primary securement means shall be screws.

RADION keyfobs

To comply with UL 1023, RADION keyfobs shall be programmed with Forced Arm Bypass Max set to 0.

3.3 B810 installation

Use the provided anchors and screws to mount the receiver in locations accessible for future maintenance. Mount the receiver onto a wall.

For best receiver reception results, place the receiver in a central location among the transmitters. For optimal communication results in situations where there is a long distance between the transmitting device and the system receiver, it might be necessary to install repeaters.



Notice!

Mount the receiver in a location away from metal objects. Metal objects (duct work, wire mesh screens, boxes) reduce RF range.

3.3.1 B810 configuration

RADION Wireless System operates on a radio frequency of 433.42 MHz.

Configuring the address switch

The address switch determines the receivers numeric address value which the receiver will use to report receiver status information to the control panel. Set the address to the receiver prior to installation. Address 1 through 4 are valid address settings for the receiver. Use a slotted screwdriver to set the address switch.

Address settings

The receiver address switches provide a single-digit setting for the receiver's address. The receiver uses addresses 1 through 4. Addresses 0 and 5 through 9 are invalid and will cause the receiver to enter into an SDI2 communication error state. This will cause the receiver to be unrecognized by the control panel. Refer to your control panel documentation for information on the valid addresses for that control panel. The figure below shows the address switch setting for address 1.



Figure 3.1: Address switch set to 1

3.3.2 Base mounting installation

Some consideration and planning are required when locating a position to mount the base of the receiver onto the desired surface. The base must be mounted in such a way that provides plenty of accessible space to insert a flat-headed screwdriver, and remove the receiver cover when maintenance and troubleshooting scenarios occur.

Because of the location of the opening mechanism on the side of the device, you will need approximately 254 mm (10 in) of clearance on one side of the base to provide easy access to the opening mechanism, and approximately 15 mm (0.6 in) of clearance on the opposite side to compensate for the physical dimensions of the device cover. This should allow for adequate space in which the device cover can be opened, and the cover removed, should the need arise.

Other mounting considerations include;

- Minimum clearance above the location to compensate for the vertical sliding movement to attach or remove the device from the base is: >30 mm (1.2 in).
- Minimum clearance below the location where the base is mounted: >23 mm (0.9 in).

3.3.3 Wiring considerations



Notice!

Do not install long cable runs next to high-current power feeds. Keep cable lengths as short as possible to minimize noise pickup.

Ensure that the wiring used meets the following specifications:

- Four-conductor unshielded 0.65 mm (22 AWG) to 2.0 mm (18 AWG) maximum.
- Wire length must not exceed 243 m (800 ft) from the control panel




Figure 3.2: Wiring the receiver to an SDI2 compatible control panel

1 – SDI2 compatible control panel
2 – Terminal wiring
3 – RADION receiver SD mounting base
4 – Module terminal block

3.3.4

Programming wireless points in the control panel

After completing the physical installation of the RADION system, you must configure the RADION points in order to establish communication between the RADION system and the supported control panel. This can be accomplished by using one of two methods:

- Using Remote Programming Software (RPS) on a supported laptop computer, or
- Compatible keypad devices to enable your points

A “point” can be a detection device, or a group of devices connected to your security system. The first step to enable communication is to verify that the RADION transmitter is programmed into the supporting control panel. This is achieved by configuring a point source index as wireless.

RFID programming from a supported keypad is achieved by two methods;

- Through the point source/RFID menu options, or
- Enroll point RFID for wireless points – which uses the “Auto-Learn” methodology.

The preferred method of entering in the RFID number would be to enter it in manually via the keypad – point source/RFID, or RPS. Doing so gives you greater control and security, while reducing the risk of incomplete RFID programming.

Not every scenario can be documented regarding various supporting panels and keypads. The workflow listed below is a generic representation of the programming/enablement process. Refer to the *Points Menu Parameters* section inside the *Keypad Installer Menu* chapter of the *B5512/B4512 and/or D9412GV4/D7412GV4 v2.xx Series Installation and System Reference Guides*, or *Points – Point Assignments in RPS Help File* for more information.

Point source/RFID programming

A point's source gives a description as to the physical location of the point for installation and service personnel. Perform the following to program a source:

1. Using either RPS, or a supported keypad, access the Program Menu, and select the **Points** menu option.
2. Select the **Source** menu option
3. Select the point source of the device you are programming.
4. Change the point source to the "wireless" option.
5. Save changes.
6. Select the **RFID** menu option to edit the RFID of each RADION device.
7. Manually enter in the unique RFID as it appears on the RFID sticker in the illustration below. ID's beginning with a zero may not display in the keypad UI, or RPS
8. Save changes and exit the menu.

The control panel is now enabled to receive wireless communication information from the RADION transmitter.




Figure 3.3: RFID sticker example (RFDW-SM-A shown)

Point indexes

Point indexes determine how points operate/respond to circumstances within a system. Perform the following to program a point:

1. Using either RPS, or a supported keypad, access the **Program Menu**, and select the **Points** menu option.
2. Select the point source of the device you are programming and select the wireless device type. Ensure that it matches that of the physical device you are enrolling.
3. Assign the desired attributes of the point index (how the device will respond to various circumstances).
4. Save changes and exit the menu.

Signal strength test (for repeaters)

Use the following procedure to test the frequency strength and range of the RADION system.

1. From the keypad, access the **Wireless Menu**, and select the **Diagnostics** menu option.
2. Select the **RF Repeaters** menu option.

3. Select the **Signal** menu option and choose the desired repeater. Various sub-categories display including:
 - Signal Strength
 - Level
 - Margin
4. When finished, exit the menu.

3.3.5

Enroll point RF ID for wireless points (Auto-learn mode)

A second option exists whereby new devices are discovered on the system. This option is referred to as the “Auto Learn Mode” option. Auto Learn Mode is the process through which the control panel identifies and enrolls new device RF ID’s that appear within the system. This is achieved by the following:

- Keyfobs – when the keyfob buttons are pressed, then released.
- Motion detectors – when the battery is inserted, or if coverage pattern is disturbed by someone walking through the coverage pattern field.



Notice!

The Auto Learn mode option is not recommended as the preferred method of entering in the RF ID’s due to the potential of the RADION system picking up the first available RF ID it detects. For optimal results, manually enter in the RF ID’s through the supported keypad, or via RPS.

Enrolling a wireless point RF ID

Using a supported keypad, enroll the RF ID through the Wireless menu option. Use the **Wireless** menu to add, replace, remove, and diagnose points and repeaters.

Perform the following to enroll in the RF ID:

1. From the keypad, access the **Wireless Menu**, and select the **Points** menu option. If adding a repeater, select the **Repeater** menu option.
2. Select the option for enrolling a point RFID.
3. When asked, select the point source you are enrolling).
4. Initiate activity for the desired device (walk through the coverage pattern if enrolling a motion detector, or press the button on the keyfob if enrolling a keyfob, open the door or window if enrolling a contact). By doing so, the control panel recognizes the first RFID it comes in contact with.
5. When the keypad or RPS shows *Point Enrolled*, exit out of the application.
6. Verify the RFID displayed on the keypad matches the RFID sticker that appears on the activated device.

3.3.6

Walk test (for motion detectors)

Use the following pattern testing procedure to test the detector range and functionality.



Notice!

Also see *Control Panels (D9412GV4/D7412GV4 v2.00) SIA CP-01 Quick Reference Guide* P/N: F. 01U.265.466, and/or *Control Panels (B5512/B4512) SIA CP-01 Quick Reference Guide* P/N: F. 01U.265.464.

Motion walk test

Remove and replace cover to activate a 90-sec Walk Test Mode. During this Test Mode, any activity in the sensor's coverage pattern will cause a transmitted alarm and LED activation. Each alarm will also extend the Test Mode for an additional 90-sec. Walk Testing should be done across the coverage pattern. The edge of the coverage pattern is determined by the first flash of the LED. This may change slightly depending upon the sensitivity setting. Walk Test the unit from both directions to determine the pattern boundaries. Although generally not required, if masking is desired, the lens diagram shows the appropriate areas to be masked. Use an opaque material (such as, electrical tape) to mask the desired areas.

Final test

While the detector is in the Walk Test Mode, turn on all heating and air conditioning sources which would normally be active during the protection period. Stand away from the sensor and outside the coverage pattern and watch for alarms. After setup and tests are completed, and there has been no activity in the sensor's coverage pattern for approximately 90-sec, the LED will flash to indicate that the Walk Test mode is ending.

Maintenance

At least once a year, a walk test should be performed to verify the range and coverage for proper operation.

Magnet walk test

Perform a magnet test to ensure proper functionality of the door and window contacts. Magnet testing can be performed by opening or closing the door/window in which the magnet is installed. In this test, you are verifying the distances of which the magnet engages and disengages the transmitter.

3.3.7**Signal level and margin**

The signal level and margin (ambient signal) of the RADION system is dependant on the location in which the B810 receiver and transmitters communicating with it are installed. Installing the receiver in an environment that has a lot of radio transmitter communication or other exterior disturbances, may reduce the receiver signal strength and margin signal of the B810 receiver.

Signal Level is a measure of how loudly a RADION receiver is hearing a message from a RADION transmitter; this value is displayed as a percentage with a range of 0% - 99%.

Signal Margin is a measure of how well a RADION receiver is hearing a message from a RADION transmitter given the current ambient noise levels, or 'white noise' at the receiver.

This value is displayed as a percentage with a range of 0% - 99%.

The concept of signal margin can be related to two people conversing in a room; when the room is quiet they hear each other clearly and the "signal margin" would be very high. In a noisy room they would not be able to hear each other as clearly and the "signal margin" would be much lower. When the signal margin is low enough conversation is no longer possible.

The RADION receiver will continually monitor the signal level of every system transmitter and report an interference trouble (sometimes called Jamming) if the signal margin of a transmitter is reduced to the point where communications may be lost.

To ensure reliable system communications, the signal level and margin of every transmitter, including repeaters, should be tested and verified to be reporting "good" at the time of installation and in the unlikely event of a interference trouble report.

Signal strength test (for Points and Receiver)

Use the following procedure to test the frequency strength and range of the RADION system.

1. From the keypad, access the **Wireless Menu**, and select the **Diagnostics** menu option
2. Select the **RF Points** menu option.

3. Select the **Signal** menu option and choose the desired option. Various sub-categories display including:
 - Signal strength
 - Level
 - Margin
4. When finished, exit the menu.

Signal strength test (for Repeaters)

Use the following procedure to test the frequency strength and range of the RADION system.

1. From the keypad, access the **Wireless Menu**, and select the **Diagnostics** menu option
2. Select the **RF Repeaters** menu option.
3. Select the **Signal** menu option and choose the desired repeater. Various sub-categories display including:
 - Signal strength
 - Level
 - Margin
4. When finished, exit the menu.



Notice!

For UL installations, the signal shall be checked to display “good.”

3.3.8

Complete the installation

Depending on the results of testing the RADION system from a system-wide approach (walk test, signal strength and margin tests), make the appropriate modifications/adjustments to complete the install process.

3.3.9

B810 system test

Overall system test

It is recommended by UL to test the entire system at least once every year, including the B810 receiver by an installer to ensure proper functionality of the RADION system.

3.4

External LED states

The receiver utilizes the External LED to show various states of the receiver. These states fall into the following three categories:

- Normal State
- Communication Error State
- Trouble State
- Maintenance state
- Off state

Normal state:

The receiver enters a normal state when it has passed all power self-tests and has established a communication link with the control panel . The receiver remains in this state as long as the communication link is present, and no other issues are present that would prevent the receiver from operating in a normal condition.

LED condition	State description
On (Normal)	Indicates the receiver is functioning normally.
Continuous slow flash: 1 sec On, 1 sec Off	Indicates the receiver is being programmed with the zone and transmitter ID's from the compatible control panel.
Turns Off momentarily	Indicates the receiver obtained a valid transmission from a RADION transmitter.
Flash 3 times	Indicates the receiver has obtained a new device ID while in "Learn Mode."

Communication error state:

The receiver enters a communication error state when, during power up, it does not establish a link with the control panel, or has been in an idle state for more than 30 sec without communication. Another cause for a communication error state is an invalid address switch setting (0, or 9).

LED condition	State description
3-pulse flash: A 3-pulse signal, followed by a short delay at the end of the 3 rd pulse (Communication error)	Indicates the receiver has experienced a communication failure. This error could be a result of either: <ul style="list-style-type: none"> - A communication failure between the control panel and receiver, or - An invalid address switch setting

Trouble state:

The receiver enters a trouble state when an internal self-test detects a failure. Another cause for the receiver entering into a trouble state would be if the receiver detects radio frequency interference failure.

LED condition	State description
Continuous fast flash: A continuous pulse between On and Off states (Trouble state)	<ul style="list-style-type: none"> - Indicates the receiver is in a trouble state, experiencing a radio frequency interference failure - A communication failure with internal hardware components within the receiver

Maintenance state

The receiver enters a maintenance state when the address switch settings are set between switch 5 – switch 8.

LED condition	State description
Continuous Flash: A continuous pattern of short off time, followed by long on time.	Indicates the receiver is in Maintenance Mode.

Off state

Indicates there is a power failure to the receiver. Check the wire connections for proper wiring.

3.4.1**LEDs**

The receiver utilizes an external LED indicator to status the operation of the receiver. Refer to the table below for LED descriptions.

LED condition	Pattern description
On (Normal)	Indicates the receiver is functioning normally.
Off	Indicates there is a power failure to the receiver, or that the receiver is not wired correctly.
Continuous Flash: 1 sec On, 1 sec Off	Indicates the receiver is being programmed with the zone and transmitter ID's from the compatible control panel.
Turns Off momentarily	Indicates the receiver obtained a valid transmission from a RADION transmitter.
Continuous Flash: A 3-pulse signal, followed by a short delay at the end of the 3 rd pulse (Communication error)	Indicates the receiver has experienced a communication error and/or a self-test failure. This error could be a result of either: <ul style="list-style-type: none"> - A communication failure between the control panel and receiver, or - An invalid address switch setting.
Continuous Flash: A continuous pulse between On and Off states (Trouble state)	<ul style="list-style-type: none"> - Indicates the receiver is in a trouble state, experiencing a radio frequency interference failure. - A communication failure with internal hardware components within the receiver
Flash 3 times:	Indicates the receiver has obtained a new radio frequency ID while in "Learn Mode".

3.5**Specifications (B810)**

Housing dimensions (H x L x D)	209.60 mm x 139.70 mm x 31.80 mm (8.25 in x 5.50 in x 1.25 in)
Power/voltage	10 -14 VDC, 12 VDC nominal
Maximum current draw	70 mA
Device testing	To ensure proper functionality, the device must be tested at least once every year by an installer.
Operating environment	0° C to +49° C (+32° F to +120° F)
Relative humidity	Up to 93% non-condensing
Frequency	433.42 MHz
Wiring distance	Maximum distance of 243 m (800 ft) from the control panel

Wiring gauge	0.65 mm (22 AWG) to 2.0 mm (18 AWG) maximum
Compatible SDI2 control panels	GV4 Series v2.00 and above (D9412GV4, D7412GV4) B5512 B4512 B3512
Wall and cover tamper switch	Transmits a tamper signal when someone removes the device from its base or pulls it away from the wall.

Table 3.1: Specifications

3.5.1 Battery requirements

Use sealed lithium or alkaline batteries for supported RADION wireless system peripherals. Replace the batteries annually to ensure optimal performance.



Notice!

Dispose of used batteries according to manufacturer’s instructions.



Warning!

The batteries used in the RADION transmitters might present a risk of fire or chemical burn if mistreated. Do not recharge, disassemble, heat above 100° C (212° F), or incinerate. Replace battery with battery manufacturer’s name or end product manufacturer’s name and part number only. Use of another battery might present a risk of fire or explosion.

Battery requirements

RADION Device	Battery Size	Battery Type	Cell Voltage	Quantity (Cells)
B810 receiver	None			
RFPR-12-A PIR motion detector	CR123A	Lithium	3 VDC	1
RFPR-C12-A PIR motion detector	CR123A	Lithium	3 VDC	1
RFPR-A repeater	Non-replaceable	Lithium polymer	3.7 VDC nominal	1
RFSM-A smoke detector	CR123A	Lithium	3 VDC	2
RFUN-A universal transmitter	CR123A	Lithium	3 VDC	1
RFBT-A bill trap	AAA	Lithium	1.5 VDC	1
RFDL-11-A TriTech detector	AA	Alkaline	1.5 VDC	4

RADION Device	Battery Size	Battery Type	Cell Voltage	Quantity (Cells)
RFDW-RM-A recessed door/window contact	AAA	Lithium	1.5 VDC	1
RFDW-SM-A standard door/window contact	AAA	Lithium	1.5 VDC	1
RFGB-A glass break	CR123A	Lithium	3 VDC	1
RFKF-TB-A key fob RFKF-FB-A key fob	CR2032 (coin cell)	Lithium	3 VDC	1
RFPB-SB-A panic button RFPB-TB-A panic button	CR2032 (coin cell)	Lithium	3 VDC	1

Table 3.2: Battery requirements

4 RADION repeater

The RFRP-A is a combined receiver and transmission device that improves the overall transmission, communication, and reliability capabilities of its assigned compatible receiver.

An LED on the front provides device status.

Features include:

- LED Display
- Cover and Wall Tamper protection



Notice!

The repeater is designed to improve the communication performance of the RADION wireless portfolio, and not to extend the range of the wireless devices. Install the transmitters within the suggested range for optimal performance and reliability.



Notice!

Use a supported transformer as defined in the specification table for the repeater. Do not connect power supply to a receptacle controlled by a switch.

4.1 Installation considerations

Use the provided anchors and screws to mount the repeater in locations accessible for future maintenance. Mount the repeater onto a wall.



Notice!

Mount the repeater in a location removed from metal. Metal objects (duct work, wire mesh screens, boxes) reduce RF range

4.2 Wiring considerations



Notice!

Do not install long cable runs next to high-current power feeds. Keep cable lengths as short as possible to minimize noise pickup.

Ensure that the wiring used meets the following specifications:

- Two-conductor unshielded wire.
- The minimal requirement for wire length is 1.83 m (6 ft) from the repeater

4.3 Specifications

Dimensions	139.70 mm x 209.60 mm x 31.80 mm (5.50 in x 8.25 in x 1.25 in)
Compatible plug-in transformers RFRP-A:	
<ul style="list-style-type: none"> – BOSCH CX4010 Plug-in Transformer – F.01U.020.504 (110 VAC primary voltage input, 18 VAC, 22 VA) – BOSCH D1640 Plug-in Transformer – 4.998.125.832 (16 VAC, 40 VA) – MG Electronic (MGT-1640), primary rated 120 VAC, 60 Hz, 0.48 Amps, secondary rated 16.5 VAC, 40 VA – Codex (SEP-1640), primary rated 120 VAC, 60 Hz, 0.48 Amps, secondary rated 16.5 VAC, 40 VA – TDC Part No (DA-22-18), primary rated 120 VAC, 60 Hz, 30 Va, secondary rated 18 VAC, 1.3 Amps, 22 VA 	
Power/Voltage (Standby battery) RFRP-A	16.5 VAC, 40VA (~) Rated 3.7 VDC, 3050mAH EVE ENERGY CO Part No P0046-LF (Not user replaceable). For standby battery to be operative, the tamper switch is required to be engaged.
Transformer power/voltage	120VAC, 60 Hz, 30 Va, or 120VAC, 60 Hz, 0.48 Amps
Current Draw	60 mA
Wire Gauge	0.65 mm (22 AWG) to 2.0 mm (18 AWG)
Temperature (operating)	0° C to +49° C (+32° F to +120° F)
Relative Humidity	0% to 93% (non-condensing)
Device testing	To ensure proper functionality, the device must be tested at least once every year by an installer.
Wall and Cover Tamper Switch	Transmits a tamper signal when someone removes the device from its base or pulls it away from the wall.
Frequency	433.42 MHz

Table 4.1: Specifications

4.4 LEDs

The repeater utilizes an external LED indicator to status the operation of the repeater. Refer to the table below for LED descriptions.

LED Condition	Pattern Description
On (Normal)	– Indicates the repeater is functioning normally.
Off	– Indicates there is a power failure to the repeater, or that the receiver is not wired correctly.
Continuous Flash: 1 sec rate for 5 sec	– Indicates the repeater is being powered up, and conduction manufacturing test initializations.

LED Condition	Pattern Description
Continuous Flash: A 3-pulse signal, followed by a short delay after the 3 rd pulse	– Indicates the repeater has experienced a low battery condition.
Continuous Flash: A 2 flash pattern continuous pulse between On and Off states with a short delay after the 2 nd pulse	– Indicates an AC power failure is detected. – A communication failure within internal hardware components inside the receiver

5 RADION glassbreak

The RFGB-A is a wireless transmitter used for detecting breaking glass. Throughout this document, the term “glassbreak” refers to glass break.

Features include:

- Monitored battery status
- Four sensitivity settings


Dimension	101.42 mm x 112.90 mm x 35.00 mm (3.99 in x 4.44 in x 1.38 in)		
Power/Voltage	Battery/CR123A, 3 VDC ()		
Battery replacement	Duracell DL123A, Lithium, Panasonic CR123A Lithium, or Sanyo CR123A Lithium. Check your battery yearly to ensure proper functionality.		
Battery life	Up to 5 years		
Device testing	To ensure proper functionality, the device must be tested at least once every year.		
Acoustic Capabilities	Glass types and thickness	Type	Thickness
		Plate	2.4 mm to 6.4 mm (3/32 in to 1/4 in)
		Tempered	3.2 mm to 6.4 mm (1/8 in to 1/4 in)
		Laminated	3.2 mm to 6.4 mm (1/8 in to 1/4 in)
		Wired	6.4 mm (1/4 in)
	Minimum pane size for all types of glass	1.2 m (4 ft)	
Microphone	Omni-directional 360° electret		
Operating Temperature	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to+120° F)		
Relative Humidity	0% to 93% (non-condensing)		
Wall and Cover Tamper Switch	Transmits a tamper signal when someone removes the device from its base or pulls it away from the wall.		
Frequency	433.42 MHz		

Table 5.1: Specifications

5.1 Installation considerations

For the best detector performance, select a mounting location that is:

- Mounted on the ceiling within a maximum range of 20 ft (6 m)

- For armor-coated glass installations, mount the sensor no more than 12 ft (3.65 m) from the glass
- Mount the detector in the direct line of sight of the glass to be protected
- On an opposite, or adjoining wall, within a range of 20 ft (6 m) for plate, tempered, laminated, and wired glass
- In a suitable environment: temperature between -18 and 50° C (0 and 120° F); and humidity between 10 and 90% non-condensing

Avoid mounting the detector in:

- Glass airlocks and glass vestibule areas
- Humid rooms
- Small utility rooms
- Rooms with noisy equipment (white noise) such as air compressors, bells, and power tools
- Rooms smaller than 10 ft x 10 ft (3 m x 3 m)
- Rooms with lined, insulating, or sound deadening drapes
- A corner of a room

Avoid locations that expose the detector to possible false-alarm sources such as:

- Glass airlocks and vestibule areas;
- Kitchens;
- Corner mounting;
- Residential car garages;
- Stairwells
- Bathrooms; and
- Small acoustically live rooms



Notice!

Glass break detectors are intended only as a component of a perimeter protection system. They should always be used in conjunction with motion sensors.

5.2 Testing

Test the detector at least once each year. Test the detector with the Sentrol 5709C hand-held tester to set the sensor into test mode. Set the tester to tempered glass, hold the speaker directly on top of the sensor, and activate the tester. The sensor alarms, and then goes into test mode for one minute. When in test mode, the LED on the sensor blinks continuously. Extend the test mode time by holding the speaker directly over the sensor at least once a minute.

5.2.1 Test the sensor

Test mode

To test the sensor, perform the following:

1. Use the 5709C hand-held tester to put the sensor into test mode
2. Set the tester to tempered glass and hold the tester on top of the sensor.
3. Activate the tester. The sensor alarms and goes into test mode for one minute. During test mode, the LED blinks continuously. To extend test time, fire the tester at the sensor at least once a minute.

**Notice!**

If blinds or drapes are present, test the area by holding the hand-held tester behind the closed blinds or drapes.

Sensor test

The sensor must be in test mode (blinking). To test the sensor, perform the following:

1. Set the tester for tempered, or laminated, unless the protected glass is plate glass.
2. Hold the tester near the surface of the glass to be protected and aim the speaker at the sensor. Be sure the tester is at the point on the glass farthest from the detector.
3. Press the test button on the tester. The LED on the sensor stays on for 4 sec to indicate the glass is within detection range of the sensor. If the LED does not stay in a solid state momentarily, but continues to blink, adjust the positioning of the sensor so that it is closer to the window, and re-test. Also check the battery strength of the hand-held testing device.




Figure 5.1: Testing behind curtains

The sensor switches from test mode to normal mode when there is at least 1 min of silence from the hand-held tester.

**Notice!**

When the detector is in normal mode, the LED will not blink unless a loud sound is detected.

In normal mode, the sensor will not trip to the tester, unless the tester is held next to the sensor. Each time the sensor alarms, it also goes into test mode for one minute. Room acoustics can artificially extend the range of a glassbreak sensor.

The specified range of the sensor has been established for worst-case conditions. While the sensor will likely function at additional range, it may miss a minimum output break, or room acoustics may change at some future time, bringing the sensor range back into normal 20 ft. (6 m) conditions. Do not exceed the rated range of the sensor, regardless of what the tester shows.

5.2.2 **Hand clap test**

Operational status of the glassbreak can be verified by performing a simple hand clap test to ensure proper functionality of the sensor.

Performing the hand clap:

1. Hand clap loudly under the sensor. The LED blinks twice.
2. Verify that the LED blinks twice.
3. Performing this simple test verifies that the microphone is operating, and that there is power to the sensor.

5.3 **Low battery**

When a low battery state is detected, the detector measures the battery, and sends a report to the receiver/control panel.

5.4 **Wall Tamper Tab**

Use the wall tamper tab to activate an alarm when the glass break has been removed from the wall.

5.5 **Maintenance**

Clean the cover with a damp (water) cloth as needed to keep it free of dust and dirt. Always test the sensor after cleaning it.

6 RADION TriTech

The RFDL-11-A is a motion detector which uses artificial intelligence to detect motion and provide immunity to false alarms. An integral RF transmitter reports low battery and tamper status, and sends a supervisory signal to the control panel. Features include:

- 11m x 11m (35 ft by 35 ft) coverage
- Flexible mounting height
- Compatible with Bosch RADION wireless systems
- Draft and Insect immune
- Cover activated tamper indication. Optional wall-activated tamper is included

Dimension	138.00 mm x 72.00 mm x 64.00 mm (5.43 in x 2.83 in x 2.52 in)
Relative humidity	0% to 93%, (non-condensing)
Temperature (operating)	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to+120° F)
Internal coverage directionality	Vertical: -4° to -10°
Sensitivity selection	Field selectable for standard or intermediate sensitivity
Power/voltage	Four AA Alkaline batteries, 1.5 VDC (— — —). 1.5 VDC x 4 = 6 VDC total.
Battery replacement	Duracell MN1500, Panasonic AM-3PIX. Check your battery yearly to ensure proper functionality.
Battery life	Up to 5 years
Device testing	To ensure proper functionality, the device must be tested at least once every year by an installer.
Wall and cover tamper switch	Transmits a tamper signal when someone removes the device from its base or pulls it away from the wall.
Frequency	433.42 MHz

Table 6.1: Specifications

6.1 Mounting height and range adjustment

Loosen the vertical adjustment screw. Adjust the board to the desired angle. Choose mounting height and desired range, and set the vertical angle. Reference the table below for proper height and adjustment values.

Mounting height	Range	
	6.1 m (20 ft)	10.7 m (35 ft)
2 m (6.5 ft)	-7°	-5°

2.1 m (7.0 ft)	-9°	-6°
2.4 m (8.0 ft)	-10°	-7°



Notice!

The mounting height must be 2 m (6.5 ft) and the vertical angle must be set at -5° for installations containing pets.

The vertical adjusting screw must be securely tightened after setting the angle.

6.2 Sensitivity settings

6.2.1 Standard sensitivity

Use this setting when pets are present in the monitored area. Standard sensitivity provides excellent detection performance and is the least sensitive to false alarms.

6.2.2 Intermediate sensitivity

Only use this setting in non-pet installations with minimal environmental disturbances. Intermediate sensitivity provides the highest level of detection performance.

6.3 Walk testing



Notice!

To maximize battery life, the LED elements do not activate unless the unit is in the Walk Test mode.

Perform a walk test to determine the boundaries of the coverage area. Perform this test at the time of installation and monthly thereafter. To ensure continual daily operation, instruct the end user to walk through the far end of the coverage pattern. This ensures an alarm output prior to arming the system.

Start Walk Test mode from the detector. Insert a slotted screwdriver to open the detector cover and then close the detector cover to start a 90-sec Walk Test mode.



Notice!

In the normal operating mode, an alarm can be transmitted only after three (3) minutes have passed since the previous alarm restoral. This 3 minute lockout time reduces unnecessary RF transmissions in high traffic areas, thereby extending battery life.


During this test mode, motion detected within the detector’s coverage area causes a transmitted alarm and LED activation. Each alarm will also extend the Test Mode. Watch for the green LED to indicate the edges of the Microwave pattern. Adjust as necessary. Please reference the LED table below for LED descriptions.

LED Condition	Cause
Steady LED	PIR activation (Walk Test)
Steady green	Microwave activation
Steady blue	Alarm signal

LED Condition	Cause
Flashing blue	Warm-up period after power-up
No LED upon initial power up	PIR failure. Replace unit.

Walking Testing the system

1. Start at the pattern’s expected boundary and walk across the pattern moving closer to the detector. Set the adjustment as low as possible for proper catch performance.



2. Adjust the Microwave Range Adjustment Potentiometer to as low a setting as possible for proper catch performance.




Figure 6.1: Sensitivity settings

1 - Alarm LED (blue, green, or red)
2 - Microwave Range Adjustment Potentiometer

3. At each pass, observe the color on the Alarm LED (refer to the *Sensitivity settings* figure above).
4. Walk test from the opposite direction to determine the coverage pattern boundaries from both sides.
5. When walk test is completed, the detector returns to normal operation after 90 sec of inactivity.

7 RADION PIR

The RFPR-12-A is a high performance PIR motion detector that uses advanced signal processing. An integrated wireless transmitter sends a battery report with each transmission, and transmits a supervisory signal to the control panel. Features include:

- 12 m x 12 m (40 ft x 40 ft) coverage
- Flexible Mounting Height


Dimensions	111.00 mm x 60.00 mm x 43.00 mm (4.40 in x 2.40 in x 1.70 in)
Relative humidity	0% to 93%, non-condensing
Temperature (operating)	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to+120° F)
Power/voltage	One CR123A Lithium battery, 3 VDC ()
Battery replacement	Duracell DL123A , Panasonic CR123A, or Sanyo CR123A. Check your battery yearly to ensure proper functionality.
Battery life	Up to 5 years
Device testing	To ensure proper functionality, the device must be tested at least once every year by an installer.
Wall and cover tamper switch	Transmits a tamper signal when someone removes the device from its base or pulls it away from the wall.
Frequency	433.42 MHz

Table 7.1: Specifications

7.1 Walk testing

Perform a walk test to determine the boundaries of the coverage area.

Insert a slotted screwdriver into the designated hole to open the cover and then close the detector cover to start a 90-sec Walk Test mode.

During this test mode, motion detected within the detector’s coverage area causes a transmitted alarm and LED activation. Each alarm will also extend the Test Mode. Adjust as necessary.



Notice!

Excessive use of the Walk Test Mode may reduce battery life. Use only for initial setup and maintenance testing.



Notice!

In the normal operating mode, an alarm can be transmitted only after three (3) minutes have passed since the previous alarm restoral. This 3 minute lockout time reduces unnecessary RF transmissions in high traffic areas, thereby extending battery life.

Refer to the LED table below for LED descriptions.

LED condition	Cause
Steady blue	PIR activation (Walk Test)
Flashing blue	Warm-up period after power-up
Flashing blue (four-pulse sequence)	PIR failure. Replace unit.




Figure 7.1: Walk test

1. Start at the pattern's expected boundary and walk across the pattern moving closer to the detector (*refer to the Walk test figure above*).
2. While the detector is in the Walk Test Mode, turn ON all heating and air conditioning sources which would normally be active during the protection period. Stay away from the sensor and outside the coverage pattern and watch for alarms.
3. The LED flashes at the completion of a 90-sec span of time, indicating that the Walk Test mode is ending. This occurs when there is no activity in the sensor's coverage pattern during the 90-sec interval.
4. When walk testing is completed, the detector returns to normal operation after 90 seconds of inactivity.

8 RADION PIR C

The RFPR-C12-A is a high performance curtain PIR motion detector that uses advanced signal processing to provide outstanding catch performance and unsurpassed false alarm immunity. The detector contains an integrated RF transmitter. The transmitter sends a battery report with each transmission, and transmits a supervisory signal to the control panel. Features include:

- 12 m x 1.5 m (40 ft x 5 ft) curtain coverage
- Flexible Mounting Height


Dimensions	111.00 mm x 60.00 mm x 43.00 mm (4.40 in x 2.40 in x 1.70 in)
Relative humidity	0% to 93%, non-condensing
Temperature (operating)	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to+120° F)
Power/voltage	One CR123A Lithium batteries, 3 VDC ()
Battery replacement	Duracell DL123A, Panasonic CR123A, or Sanyo CR123A. Check your battery yearly to ensure proper functionality.
Battery life	Up to 5 years
Device testing	To ensure proper functionality, the device must be tested at least once every year by an installer.
Wall and cover tamper switch	Transmits a tamper signal when someone removes the device from its base or pulls it away from the wall.
Frequency	433.42 MHz

Table 8.1: Specifications

8.1 Walk testing

Perform a walk test to determine the boundaries of the coverage area. Insert a slotted screwdriver into the designated hole to open the cover and then close the detector cover to start a 90-sec Walk Test mode. During this test mode, motion detected within the detector’s coverage area causes a transmitted alarm and LED activation. Each alarm will also extend the Test Mode. Adjust as necessary.



Notice!

Excessive use of the Walk Test Mode may reduce battery life. Use only for initial setup and maintenance testing.

**Notice!**

In the normal operating mode, an alarm can be transmitted only after three (3) minutes have passed since the previous alarm restoral. This 3 minute lockout time reduces unnecessary RF transmissions in high traffic areas, thereby extending battery life.

Refer to the LED table below for LED descriptions.

LED condition	Cause
Steady blue	PIR activation (Walk Test)
Flashing blue	Warm-up period after power-up
Flashing blue (four-pulse sequence)	PIR failure. Replace unit.




Figure 8.1: Walk test

1. Start at the pattern's expected boundary and walk across the pattern moving closer to the detector (*refer to the Walk test figure above*).
2. While the detector is in the Walk Test Mode, turn ON all heating and air conditioning sources which would normally be active during the protection period. Stay away from the sensor and outside the coverage pattern and watch for alarms.
3. The LED flashes at the completion of a 90-sec span of time, indicating that the Walk Test mode is ending. This occurs when there is no activity in the sensor's coverage pattern during the 90-sec interval.
4. When walk testing is completed, the detector returns to normal operation after 90 seconds of inactivity.

9 RADION smoke

The RFSM-A is a non-latching wireless smoke detector that sends an alarm signal to the receiver.

The following features include:

- A visual status LED
- A built-in sounder for alarm alerts
- Under normal conditions, the red LED flashes once every 8 sec while the sensor monitors the surrounding environment. When the sensor detects smoke, the LED changes from flashing to steady ON and the sounder produces a loud, continuous tone. Refer to the LED table for more information.

Replaceable optical chamber	For easy maintenance
Power/voltage	Two CR123A Lithium batteries, 3 VDC (==)
Current draw	Standby: 45 uA Alarm: 70 mA
Battery replacement	Duracell DL123A, Panasonic CR123A, or Sanyo CR123A. Check your batteries yearly to ensure proper functionality.
Battery life	Minimum of 5 years or greater
Device testing	To ensure proper functionality, the device must be tested at least once every year.
Sensitivity	0.14+/- 0.04 bM/m (0.97 – 2.99%/ft obscuration – RFSM-A only)
Temperature (operating)	Functional range: -10° C to +49° (+14° F to +120° F UL only: 0° C to +49° C (+32° F to +120° F)
Relative humidity	0% to 93% (non-condensing)
Cover and wall tamper switch	Transmits a tamper switch signal when the detector is removed from its base, or the unit is pulled away from the wall.
Drift compensation adjustment	-1.64%/m (0.5%/ft) maximum
Sounder	85 dBA at 3 m
Self-diagnostics feature	Monitors detector sensitivity and operational status.
Frequency	433.42 MHz

Table 9.1: Specifications




Figure 9.1: Smoke detector

1 - High intensity LED
2 - Test/Silence button

9.1 Battery replacement

Under normal conditions, the LED normally flashes every 8 sec to indicate normal operating conditions. Replace the battery when the LED stops flashing, and the sensor chirps every 45 sec.

Silence the low battery trouble chirps for 24 hr by pushing the **Test/Silence** button. Refer to the Smoke detector illustration for locating the **Test/Silence** button.

9.2 Smoke test

Test smoke detectors annually by using a listed aerosol smoke tester to simulate an alarm. Follow the instructions on the can.

The LED should remain ON while the detector provides a continuous tone. The detector automatically resets when smoke is no longer present. A detector that fails to activate with the smoke test might require cleaning or replacement.



Notice!

To avoid a fire department dispatch, contact central monitoring station, or put the system into Test mode before activating the detector using this method.

9.3 Sensitivity test



Notice!

The control panel recognizes Test Mode as a test. It does not send an alarm.

The detector includes a Sensitivity Level Test mode for determining the detector's sensitivity:

1. Press and hold the **Test/Silence** button for 4 sec. The LED flashes 1 to 9 times.
2. Count the number of LED flashes and use the *Smoke detector sensitivity conditions* table to determine the status of the detector's sensitivity and the recommended action.

Flashes	Action Recommended
1	Self-diagnostics failure. Return detector for service or replacement.
2 to 3	Detector is becoming insensitive. Clean detector and re-test. If error persists, replace the detector.
4 to 7	Detector is within normal sensitivity settings.
8 to 9	Detector is becoming too sensitive. Confirm that the smoke chamber is snapped down securely. Clean the sensor and re-test.

Table 9.2: Smoke detector sensitivity conditions

9.4 Test/Silence button

Refer to the RADION smoke detector illustration for location of the **Test/Silence** button.

- Testing. Press the Test/Silence button for 4 sec. The detector performs a Sounder test and a Sensitivity test.
- Silence alarm. Press to silence the sounder during an alarm. After a few minutes, the sounder and alarm resume if smoke is still present.

9.5 LED

LED	Status
Flashing	Flashes every 8 sec under normal operation.
ON	Detects smoke, sending an alarm.
OFF	Malfunction, replace the batteries, clean the detector, or replace the optical chamber as required.

Table 9.3: LED

9.6 Clean the detector and replace the optical chamber

Clean the detector cover with a dry or damp cloth as needed to keep it free from dust and dirt. Clean the detector interior at least yearly.

Cleaning the detector:

1. Remove the detector from the mounting base.
2. Remove the batteries.
3. Slide a slotted screwdriver into the slot on the detector cap and gently push down to pry off the cap.




Figure 9.2: Remove the detector cap

4. Squeeze the optical chamber where indicated and pull it up and away from the detector.




Figure 9.3: Remove the detector cap

1 - Optical base
2 - Optical chamber
3 - Alarm cap

5. Use compressed air or a soft-bristled brush to remove dust and dirt from the smoke chamber base.
6. Align the optical chamber with the base and snap down into place.
7. To attach the detector cap, line the cap up with the detector, press the cap onto the detector, and turn clockwise to snap it firmly into place.
8. Observing the proper polarity, install the batteries and the battery cover. If the batteries are not installed properly, the detector will not fit onto the mounting base. Ensure that the batteries are properly installed.
9. Mount the detector onto the mounting base.
10. Test the detector's sensitivity.

10 RADION contact SM

The RFDW-SM-A is a standard surface-mount wireless transmitter device used for monitoring doors and windows.

Features include:

- An internal reed switch
- A cover and wall tamper switch

Power/voltage	One AAA Lithium battery, 1.5 VDC (— — —)
Battery replacement	Energizer L92. Check your battery yearly to ensure proper functionality.
Battery life	Up to 5 years
Device testing	To ensure proper functionality, the device must be tested at least once every year by an installer.
Dimensions (transmitter)	19.50 mm x 82.55 mm x 12.80 mm (0.76 in x 3.25 in x 0.50 in)
Dimensions (magnet)	24.5 mm x 18.5 mm x 12.5 mm (0.97 in x 0.72 in x 0.49 in)
Temperature (operating)	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to+120° F)
Relative humidity	0% to 93% (non-condensing)
Wall and Cover Tamper Switch	Transmits a tamper signal when someone removes the device from its base or pulls it away from the wall.
Frequency	433.42 MHz

Table 10.1: Specifications

10.1 Installation considerations

You have a variety of installation options to consider when installing the device. You must acknowledge the unique installation approach prior to installation. Some installation considerations include:

- Suitable surfaces for installation include wood, steel, and aluminum.
- The location of the magnet and transmitter in relationship to the door/window frame dimensions. Verify you have proper clearance with the latch of the window or door you are installing the device onto. Failure to do so will make it extremely difficult to access and open the device for maintenance purposes.
- In some cases, you might need an additional spacer when installing the transmitter and magnet in the corner of a recessed door or window frame to close the gap in height between the magnet and transmitter.
- For additional security, you can use an adhesive with the screws to secure the transmitters and magnets during installation.
- When installing the magnet, verify that the notches in the magnet base, line up with the notches in the transmitter base, otherwise the magnet and transmitter do not function effectively.

- When installing the magnet base, install the face of the magnet base flush to the surface edge of the installation location. This prevents damage to the magnet plastic base whenever a window or door is opened.
- Adhere to the distances prescribed in the graphical table found in the graphical *Installation and Operation Guide* when installing the magnet adjacent to the transmitter.

How to read the Graphical Magnet Distances table

Contained in the RADION contact SM *Installation Guide* is a graphical table along with the X – Y – Z coordinates graphic. Use the table in conjunction with the graphic to determine desired distances between the magnet and the transmitter based on the type of installation (wood or metal).

**Notice!**

The content in the Installation Guide table applies to EN installations.

11 RADION contact RM

The RFDW-RM-A is a recessed-mounted wireless transmitter device used for monitoring doors and windows. Features include:

- Self-contained transmitter with magnetic reed switch
- Tamper protection
- Recessed mounting on doors or windows


Power/voltage	One AAA Lithium battery, 1.5 VDC ()
Battery replacement	Energizer L92. Check your battery yearly to ensure proper functionality.
Battery life	Up to 5 years
Device testing	To ensure proper functionality, the device must be tested at least once every year by an installer.
Dimensions (transmitter)	19.00 mm x 104.80 mm (0.75 in x 4.12 in)
Dimensions (magnet)	22 mm x 28 mm x 15 mm (0.87 in x 1.10 in x 0.59 in)
Relative humidity	0% to 93%, non-condensing
Temperature (operating)	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to+120° F)
Frequency	433.42 MHz

Table 11.1: Specifications

11.1 Installation considerations

You have a variety of installation options to consider when installing the device. You must acknowledge the unique installation approach prior to installation. Some installation considerations include:

- The installation of this device is suitable for wood surfaces. This device is not suitable for steel surfaces.
- The transmitter housing was designed to be open with a coin. Using a screwdriver may cause damage to the plastic top.
- When reinserting the PCB (battery and antenna assembly), verify that the PCB assembly fits into the grooves of the transmitter housing.
- When reinserting the plastic top, verify that the top fits into the designed grooves of the transmitter housing.
- When installing the transmitter in an overhead location, be mindful that the PCB assembly may fall out of the transmitter housing.
- The removal of the plastic flaps is optional, depending on your installation needs.
- For added security, you can use an adhesive with the screws to secure the transmitters and magnets.

How to read the Graphical Magnet Distances table

Contained in the recessed door/window contact *Installation Guide* is a graphical table along with the X - Y coordinates graphic. Use the table in conjunction with the graphic to determine desired distances between the magnet and the transmitter based on the type of installation.

12 RADION specialty

RFBT-A is a designed transmitter (bill trap) specifically used in financial or retail environments. It transmits a silent, wireless alarm signal without local notification (no LED activation) when a bill, or any other form of paper currency is removed from the transmitter – typically, the last bill in the bottom of a cash drawer.

Features include:

- Brief illumination of LED to signify armed and operational status
- Wall tamper alarm when removed from the cash drawer.

Dimensions	48.80 mm x 154.10 mm x 23.60 mm (1.92 in x 6.06 in x 0.93 in)
Power/voltage	1.5 VDC, Lithium (==)
Battery replacement	Energizer L92. Replace your battery yearly to ensure proper functionality.
Battery life	Up to 5 years
Device testing	To ensure proper functionality, the device must be tested at least once every year.
Relative humidity	Up to 93%, non-condensing
Temperature (operating)	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to+120° F)
Frequency	433.42 MHz

Table 12.1: Specifications




Figure 12.1: Specialty

12.1 Applications for this product

Usage of this product is to provide concealed protection against theft in a financial institution such as a bank, or in other commercial environments such as retail businesses and shops. In some cases, the cash drawer is removed from the teller or cashier station, and stored inside a bank vault at the close of each business day. In this scenario, the bank vault system is always armed, and the bill trap remains in a non-faulted condition. It is recommended to use the 3M double sided tape when inserting into the cash drawer.

In other occasions, the bill trap itself may be removed from the cash drawer at the end of a workers shift. In this situation, the bill trap unit will generate a tamper condition upon removal. In this type of application, it is important that the system must be configured such that the tamper does not generate a silent alarm. For this occasion, the hook and loop may be a more suitable mounting technique.

12.2 Installation consideration

During the installation process, use the self-adhesive Velcro strips located on the bottom of the bill trap base, to secure and stabilize the bill trap in the cash drawer. This is achieved by performing the following:

1. Separate the Velcro strips from one another.
2. Peel off the protective backing of the Velcro strips.
3. Press the two bottom sections of the Velcro onto the bottom of the cash drawer, in the desired location.
4. Line up and press down on the bill trap so that the Velcro on the bottom of the bill trap is aligned with the Velcro strips inside the cash drawer.



Warning!

It is important to check the Velcro strips on a weekly basis for wear and replace when appropriate in order to prevent potential false alarms.

13 RADION universal transmitter

The RFUN-A is a wireless transmitter used for monitoring doors, windows, and other dry contact devices.

Features include:

- A cover and wall tamper switch
- Single input with magnetic contact
- Ability to connect to an external detector


Dimensions (transmitter)	82.55 mm x 33.02 mm x 19.50 mm (3.25 in x 1.30 in x 0.76 in)
Dimensions (magnet)	24.50 mm x 18.50 mm x 12.50 mm (0.97 in x 0.72 in x 0.49 in)
Wire gauge	0.65 mm (22 AWG) to 1.5 mm (16 AWG)
Wiring distance	Maximum distance of 7.62 m (25 ft)
Power/voltage	Lithium battery, 3 VDC ()
Battery replacement	One Duracell DL123A, or Panasonic CR123A, or Sanyo CR123A. Check your battery yearly to ensure proper functionality.
Battery life	Up to 5 years
Device testing	To ensure proper functionality, the device must be tested at least once every year by an installer.
Temperature (operating)	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to +120° F)
Relative Humidity	0% to 93% (non-condensing)
Terminal block	For connecting other dry contact devices such as another magnetic reed switch.
Wall and cover tamper switch	Transmits a tamper signal when someone removes the device from its base or pulls it away from the wall.
Frequency	433.42 MHz

Table 13.1: Specifications

Single EOL Resistor Option

Use a 2.2 k-Ω EOL resistor. Refer to the diagram below.




Figure 13.1: Single EOL resistor option

1 - Normally-open (NO)
2 - Normally-closed (NC)
3 - Input disabled - no contact

13.1 Installation considerations

You have a variety of installation options to consider when installing the device. You must acknowledge the unique installation approach prior to installation. Some installation considerations include:

- The location of the magnet and transmitter in relationship to the door/window frame dimensions. Verify you have proper clearance with the latch of the window or door you are installing the device onto. Failure to do so will make it extremely difficult to access and open the device for maintenance purposes.
- In some cases, you might need an additional spacer when installing the transmitter and magnet in the corner of a recessed door or window frame to close the gap in height between the magnet and transmitter.
- On surface areas that are not conducive to mounting via the screws, you can secure transmitters and magnets using an industrial strength adhesive.
- When installing the magnet, verify that the notches in the magnet base, line up with the notches in the transmitter base, otherwise the magnet and transmitter do not function effectively.
- When installing the magnet base, install the face of the magnet base flush to the surface edge of the installation location. This prevents damage to the magnet plastic base whenever a window or door is opened.
- Adhere to the distances prescribed in the graphical table found in the graphical *Installation and Operation Guide* when installing the magnet adjacent to the transmitter.

How to read the Graphical Magnet Distances table

Contained in the universal transmitter *Installation and Operation Guide* is a graphical table along with the X - Y - Z coordinates graphic. Use the table in conjunction with the graphic to determine desired distances between the magnet and the transmitter based on the type of installation (wood or metal).



Notice!

The content in the graphical table applies to EN installations.


13.2 Reed switch settings

Set the detector to enable or disable the reed switch.



Notice!

Please note, insert the jumper onto the pin prior to installing the battery. Failure to do so may result in unexpected operation of the device.



Callout - Description
1 - No jumper disables the internal reed switch
2 - Jumper on enables the internal reed switch

14 RADION keyfob

RADION keyfobs (two button and four button) are personal transmitters carried by the user that allow the user to remotely arm or disarm a security area.

Dimensions	63.70 mm x 35.50 mm x 13.00 mm (2.51 in x 1.40 in x 0.51 in)
Power/voltage	One Lithium battery (CR2032) 3 VDC
Battery replacement	Panasonic CR2032, Duracell DL2032. Check your Battery yearly to ensure proper functionality
Battery life	Up to 5 years
Temperature (operating)	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to+120° F)
Relative humidity	0% to 93% (non-condensing)
Frequency	433.42 MHz

Table 14.1: Specifications



Notice!

Please note, the battery does not come installed. Refer to the specification table for the correct battery type when replacing an old battery.

Keyfob buttons

Refer to your control panel's documentation to program the functions of the programmable buttons.

Pressing either the arm or disarm button causes the LED to flash for about 2 sec., indicating the keyfob sent commands to the control panel.



Notice!

Pressing the Arm and Disarm buttons in unison for 1 sec transmits a panic alarm.

14.1 RADION keyfob FB

The RFKF-FB-A four button keyfob is designed for arming (lock icon) and disarming (unlock icon) the system remotely. You can configure the programmable buttons at the control panel for additional control functionality. To operate the programmable buttons, simply press and hold either button for at least one sec in order for the desired feature to work.

- Uniquely coded arm and disarm buttons
- Panic alarm
- LED indicator

- Programmable option buttons




Figure 14.1: Keyfob buttons and LED

1 - Arm button
2 - LED
3 - Disarm button
4 - Programmable button
5 - Programmable button

14.2

RADION keyfob TB

The RFKF-TB-A two button keyfob is designed for arming (lock icon) and disarming (unlock icon) the system remotely. To operate these buttons, simply press and hold either button for at least one sec in order for the desired feature to work.

- Uniquely coded arm and disarm buttons
- Panic alarm
- LED indicator




Figure 14.2: Keyfob buttons and LED

1 - Arm button
2 - LED
3 - Disarm button

15 RADION panic

The RFPB-SB-A/RFPB-TB-A is a transmitter that sends a panic alarm signal to the security system when one (single button panic), or both panic buttons (2-button panic) are pressed for 1 sec. The single-button, or two-button panic transmitter can be used in a variety of options such as a pendant, wrist strap, belt clip, depending on the desired accessory. The RADION panic offers the following features:

- Each transmitter has a unique code
- Panic alarm signal
- One or two button versions
- LED indicator
- Optional accessories




Figure 15.1: Panic Buttons

1 - Panic buttons
2 - LED

Relative humidity	0% to 93% (non-condensing)
Temperature (operating)	Functional range: -10°C to +49°C (+14°F to +120°F) UL only: 0° C to +49° C (+32° F to+120° F)
Dimensions	63.70 mm x 35.50 mm x 13.00 mm (2.51 in x 1.40 in x 0.51 in)
Power/voltage	One CR2032 Lithium battery, 3 VDC
Battery replacement	Panasonic CR2032, Duracell DL2032. Check your Battery yearly to ensure proper functionality
Battery life	Up to 5 years

LED	Red
Frequency	433.42 MHz

Table 15.1: Specifications**Notice!**

Please note, the battery does not come installed. Verify that the correct battery as defined in the specification table is installed in the proper polarity.









Optional Accessories	
Pendant	Pendant transmitters provide single or two-button activation confirmed by emitting LED flashes with all transmissions to clearly show users when the unit is operating. Users can wear the pendants on a neck cord. The pendants are ideal to meet the needs of patrolling guards, bank employees, and retail store employees.
Belt Clip	Belt Clip transmitters provide single or two-button activation confirmed by emitting LED flashes with all transmissions to clearly show users when the unit is operating. The single-button design is ideal for assisted living installations whereas the two-button design reduces accidental activation.
Wrist Strap	Wrist Strap transmitters provide single or two-button activation confirmed by emitting LED flashes with all transmissions to clearly show users when the unit is operating.










16





Appendices

Icons and symbols

Use the table below for descriptions of the icons and symbols used in the reference guide.

Description	Icon/symbol
Not pet friendly.	
Signifies that the item is the correct choice, selection, or location.	
Pet friendly (appropriate height and weights below graphic).	
Point away from rotating machines.	
Point away from objects that rapidly change temperature	
Do not mount the device that has direct exposure to sunlight.	
Do not point toward window.	
Intended for indoor use only.	

<p>Electrostatic discharge symbol</p>	
<p>Symbol against disposing batteries into the garbage</p>	
<p>Humidity range</p>	
<p>Temperature range</p>	
<p>Frequency range</p>	
<p>Duration of time</p>	
<p>Questions are answered in the reference guide.</p>	
<p>Universal sign for connecting or disconnecting power.</p>	
<p>Universal sign for connecting to a power source.</p>	

Battery-related information.	
Perform a walk test	
Walk test has concluded	
Device has wall tamper detection.	

Bosch Security Systems, Inc

12000 Portland Avenue South

Burnsville MN 55337

USA

www.electrovoice.com

© Bosch Security Systems, Inc, 2014